EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA)

ADDENDUM: 0800

DATE JANUARY 1995

PAGE : 1 of 7

FREQ	SKILL	JOB DESCRIPTION				
DAILY	L6	INSP. TANKS FOR LEAKS/TANK COND. (PSAPCA)				
PROPERT JOB NO.:	Y NO.: 65-050 087352	995-001 (METR	0)			
ABF 140 3-369		WEST	25,000	WASTE WATER		
ABF 141	3-369	WEST	25,000	WASTE WATER		
ABF 103	3-369	WEST	25,000	WASTE WATER		
ABF 104	3-369	WEST	25,000	WASTE WATER		
ABF 121	3-380	SOUTH	20,000	WASTE WATER		
ABF 122	3-380	SOUTH	20,000	WASTE WATER		
ABF 112	3-369	WEST	500	HYDROGEN PEROXIDE		

	6/16/95	6/19/95	6/20/95	6/21/95	6/22/95
TANK	FRIDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY
ABF 140	MC	-m/	Me	me	ML
ABF 141	MC	Me	MC	me	me
ABF 103	MC	MIC	MC	me	me
ABF 104	me	MIL	MIL	me	me
ABF 121	me	MC	MC	Mil	me
ABF 112	MC	MIL	MC	Mil	me
ABF 122	mc	Me	MC	Mil	me

- 1. INSPECT EACH TANK LISTED ABOVE, AND ASSOCIATED PIPING AND PUMPS, DAILY. INSPECT FOR LEAKAGE OR DAMAGE. CHECK INTERSTITIAL SPACE MONITOR, IF TANK IS SO EQUIPPED, FOR LEAK INDICATION.
- 2. HAND SIGN INSPECTION SHEET
- 3. NOTE ANY REPAIRS NEEDED AND DATE REPORTED.
- 4. REQUEST A WORK CLASS 22 (PLANNED JOB) FOR ANY REPAIRS REQUIRED.
- 5. FILE THIS INSPECTION RECORD AT THE ENVIRONMENTAL OPERATIONS OFFICE.

End of Page 1

BCA FACILITIES SERVICES NBF

ADDENDUM INSTRUCTIONS

EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA)

DATE JANUARY 1995

ADDENDUM: 0800 PAGE : 2 of 7

PROPERTY NO.: 65-050995-001 (METRO) JOB NO.: 087352

JOD 110... 007552

6. ENSURE STRIPPING TOWER IS CLEAR FROM OBSTRUCTIONS AND OPERATES PROPERLY.

RETURN COMPLETED ADDENDUM TO YOUR SUPERVISOR.

COMPLETED BY:

- Date:

TIME:

SUPERVISOR:

DATE:

KEEP THIS AND ALL ENVIRONMENTAL PAPERWORK TOGETHER FOR FIVE (5) YEARS.

End of Page 2